

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Jundah Potable Water	Potable water scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
Jundah Potable Water	Potable water scheme	QG1.1	AS2	Length water mains	4.7	km	
Jundah Potable Water	Potable water scheme	QG1.4b	AS47	Capacity of water treatment plants	0.15	ML/day	
Jundah Potable Water	Potable water scheme	QG1.7	AS48	Total potable water storage volume	0.7	ML	
Jundah Potable Water	Potable water scheme	QG1.23	AS56	Volume water lost: potable water	17.6	ML	Mostly consists of water used for WTP operations such as backwashing and mains scouring.
Jundah Potable Water	Potable water scheme	QG4.5	AS8	Water main breaks per 100 km water main	42.5	per 100 km water main	
Jundah Potable Water	Potable water scheme	QG4.12	CS10	Water service complaints per 1000 connections	10.6	per 1000 connections	
Jundah Potable Water	Potable water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Jundah Potable Water	Potable water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	21.3	per 1000 connections	
Jundah Potable Water	Potable water scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	21.3	per 1000 connections	
Jundah Potable Water	Potable water scheme	QG1.13	CS2	Connected residential properties: water	0.063	000s	
Jundah Potable Water	Potable water scheme	QG1.14	CS3	Connected non-residential properties: water	0.031	000s	
Jundah Potable Water	Potable water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Jundah Potable Water	Potable water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	10.6	per 1000 connections	
Jundah Potable Water	Potable water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Jundah Potable Water	Potable water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 300kL free. Excess water usage charges apply to amounts over 300kL	Text	
Jundah Potable Water	Potable water scheme	QG1.8	WA1	Volume water sourced: surface water	45.4	ML	
Jundah Potable Water	Potable water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Jundah Potable Water	Potable water scheme	QG1.5	WA201	Maximum daily demand	0.1	ML/day	
Jundah Potable Water	Potable water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Jundah Potable Water	Potable water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Jundah Potable Water	Potable water scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	35.8	ML	The difference between the water sourced and water produced/supplied into the system is the volume of water used for WTP operations such as backwashing etc.
Jundah Potable Water	Potable water scheme	QG1.17a	WA32	Volume potable water supplied: residential	6.3	ML	
Jundah Potable Water	Potable water scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	6.8	ML	
Jundah Potable Water	Potable water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Jundah Potable Water	Potable water scheme	QG1.12	WA7	Volume water sourced: all	45.4	ML	
Jundah Potable Water	Potable water scheme	QG2.10a	WS11	Water restriction duration: PWCM	365	days	
Jundah Potable Water	Potable water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Jundah Potable Water	Potable water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Jundah Potable Water	Potable water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Jundah Potable Water	Potable water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Jundah Potable Water	Potable water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Jundah Potable Water	Potable water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Jundah Potable Water	Potable water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Jundah Potable Water	Potable water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Jundah Potable Water	Potable water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Jundah Potable Water	Potable water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Jundah Potable Water	Potable water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Jundah Potable Water	Potable water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Jundah Potable Water	Potable water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Jundah Potable Water	Potable water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from Windorah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Stonehenge Potable Water	Potable water scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
Stonehenge Potable Water	Potable water scheme	QG1.1	AS2	Length water mains	2.4	km	
Stonehenge Potable Water	Potable water scheme	QG1.4b	AS47	Capacity of water treatment plants	0.01	ML/day	
Stonehenge Potable Water	Potable water scheme	QG1.7	AS48	Total potable water storage volume	0.1	ML	
Stonehenge Potable Water	Potable water scheme	QG1.23	AS56	Volume water lost: potable water	0	ML	
Stonehenge Potable Water	Potable water scheme	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
Stonehenge Potable Water	Potable water scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
Stonehenge Potable Water	Potable water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Stonehenge Potable Water	Potable water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Stonehenge Potable Water	Potable water scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	0	per 1000 connections	
Stonehenge Potable Water	Potable water scheme	QG1.13	CS2	Connected residential properties: water	0.019	000s	
Stonehenge Potable Water	Potable water scheme	QG1.14	CS3	Connected non-residential properties: water	0.015	000s	
Stonehenge Potable Water	Potable water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Stonehenge Potable Water	Potable water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
Stonehenge Potable Water	Potable water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Stonehenge Potable Water	Potable water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 300kL free. Excess water usage charges apply to amounts over 300kL	Text	
Stonehenge Potable Water	Potable water scheme	QG1.8	WA1	Volume water sourced: surface water	5.3	ML	Figure is the amount taken from the offstream storage, which is filled from the Thomson River. The take direct from the river is not metered.
Stonehenge Potable Water	Potable water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Stonehenge Potable Water	Potable water scheme	QG1.5	WA201	Maximum daily demand	0	ML/day	
Stonehenge Potable Water	Potable water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Stonehenge Potable Water	Potable water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Stonehenge Potable Water	Potable water scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	3.9	ML	The difference between the water sourced and water produced/supplied into the system is the volume of water used for WTP operations such as backwashing etc.
Stonehenge Potable Water	Potable water scheme	QG1.17a	WA32	Volume potable water supplied: residential	0.8	ML	
Stonehenge Potable Water	Potable water scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	3.1	ML	
Stonehenge Potable Water	Potable water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Stonehenge Potable Water	Potable water scheme	QG1.12	WA7	Volume water sourced: all	5.3	ML	
Stonehenge Potable Water	Potable water scheme	QG2.10a	WS11	Water restriction duration: PWCM	365	days	
Stonehenge Potable Water	Potable water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Stonehenge Potable Water	Potable water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Stonehenge Potable Water	Potable water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Stonehenge Potable Water	Potable water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Stonehenge Potable Water	Potable water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Stonehenge Potable Water	Potable water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Stonehenge Potable Water	Potable water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Stonehenge Potable Water	Potable water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Stonehenge Potable Water	Potable water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Stonehenge Potable Water	Potable water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Stonehenge Potable Water	Potable water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	3	1,2,3,4,5,6	
Stonehenge Potable Water	Potable water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Stonehenge Potable Water	Potable water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Stonehenge Potable Water	Potable water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from either Windorah or Jundah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Windorah Potable Water	Potable water scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	1	Count	
Windorah Potable Water	Potable water scheme	QG1.1	AS2	Length water mains	4.7	km	
Windorah Potable Water	Potable water scheme	QG1.4b	AS47	Capacity of water treatment plants	0.05	ML/day	
Windorah Potable Water	Potable water scheme	QG1.7	AS48	Total potable water storage volume	0.2	ML	
Windorah Potable Water	Potable water scheme	QG1.23	AS56	Volume water lost: potable water	0	ML	
Windorah Potable Water	Potable water scheme	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
Windorah Potable Water	Potable water scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
Windorah Potable Water	Potable water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Windorah Potable Water	Potable water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	24.4	per 1000 connections	
Windorah Potable Water	Potable water scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	0	per 1000 connections	
Windorah Potable Water	Potable water scheme	QG1.13	CS2	Connected residential properties: water	0.054	000s	
Windorah Potable Water	Potable water scheme	QG1.14	CS3	Connected non-residential properties: water	0.028	000s	
Windorah Potable Water	Potable water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Windorah Potable Water	Potable water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	24.4	per 1000 connections	
Windorah Potable Water	Potable water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Windorah Potable Water	Potable water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 300kL free. Excess water usage charges apply to amounts over 300kL	Text	
Windorah Potable Water	Potable water scheme	QG1.8	WA1	Volume water sourced: surface water	25.7	ML	
Windorah Potable Water	Potable water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Windorah Potable Water	Potable water scheme	QG1.5	WA201	Maximum daily demand	0	ML/day	
Windorah Potable Water	Potable water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Windorah Potable Water	Potable water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Windorah Potable Water	Potable water scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	13.4	ML	The difference between the water sourced and water produced/supplied into the system is the volume of water used for WTP operations such as backwashing etc.
Windorah Potable Water	Potable water scheme	QG1.17a	WA32	Volume potable water supplied: residential	8	ML	
Windorah Potable Water	Potable water scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	5.3	ML	
Windorah Potable Water	Potable water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Windorah Potable Water	Potable water scheme	QG1.12	WA7	Volume water sourced: all	25.7	ML	
Windorah Potable Water	Potable water scheme	QG2.10a	WS11	Water restriction duration: PWCM	365	days	
Windorah Potable Water	Potable water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Windorah Potable Water	Potable water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Windorah Potable Water	Potable water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Windorah Potable Water	Potable water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Windorah Potable Water	Potable water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Windorah Potable Water	Potable water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Windorah Potable Water	Potable water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Windorah Potable Water	Potable water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Windorah Potable Water	Potable water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Windorah Potable Water	Potable water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Windorah Potable Water	Potable water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Windorah Potable Water	Potable water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Windorah Potable Water	Potable water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Windorah Potable Water	Potable water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from Jundah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Jundah Raw Water	Raw-Partially treated water scheme	QG1.1	AS2	Length water mains	4	km	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.5	AS8	Water main breaks per 100 km water main	24.9	per 100 km water main	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.12	CS10	Water service complaints per 1000 connections	54.9	per 1000 connections	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	54.9	per 1000 connections	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.13	CS2	Connected residential properties: water	0.069	000s	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.14	CS3	Connected non-residential properties: water	0.022	000s	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
Jundah Raw Water	Raw-Partially treated water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Jundah Raw Water	Raw-Partially treated water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 700kL free. Excess water usage charges apply to amounts over 700kL	Text	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.8	WA1	Volume water sourced: surface water	77.3	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.5	WA201	Maximum daily demand	0.3	ML/day	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.12	WA7	Volume water sourced: all	77.3	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.17b	WA91	Volume raw-PT water supplied: residential	30.5	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	37	ML	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Jundah Raw Water	Raw-Partially treated water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Jundah Raw Water	Raw-Partially treated water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Jundah Raw Water	Raw-Partially treated water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from Windorah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.1	AS2	Length water mains	1.6	km	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.5	AS8	Water main breaks per 100 km water main	0	per 100 km water main	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.12	CS10	Water service complaints per 1000 connections	0	per 1000 connections	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	0	per 1000 connections	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.13	CS2	Connected residential properties: water	0.017	000s	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.14	CS3	Connected non-residential properties: water	0.013	000s	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Stonehenge Raw Water	Raw-Partially treated water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 700kL free. Excess water usage charges apply to amounts over 700kL	Text	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.8	WA1	Volume water sourced: surface water	26	ML	Figure is the amount taken from the offstream storage, which is filled from the Thomson River. The take direct from the river is not metered.
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.5	WA201	Maximum daily demand	0.1	ML/day	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.12	WA7	Volume water sourced: all	26	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.17b	WA91	Volume raw-PT water supplied: residential	6.8	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	7.1	ML	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	3	1,2,3,4,5,6	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Stonehenge Raw Water	Raw-Partially treated water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from either Windorah or Jundah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Windorah Raw Water	Raw-Partially treated water scheme	QG1.1	AS2	Length water mains	4	km	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.5	AS8	Water main breaks per 100 km water main	25	per 100 km water main	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.12	CS10	Water service complaints per 1000 connections	45.5	per 1000 connections	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	45.5	per 1000 connections	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.13	CS2	Connected residential properties: water	0.058	000s	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.14	CS3	Connected non-residential properties: water	0.03	000s	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	0	per 1000 connections	
Windorah Raw Water	Raw-Partially treated water scheme	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Windorah Raw Water	Raw-Partially treated water scheme	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 700kL free. Excess water usage charges apply to amounts over 700kL	Text	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.8	WA1	Volume water sourced: surface water	101.6	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.9a	WA2	Volume water sourced: groundwater	NR	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.5	WA201	Maximum daily demand	0.5	ML/day	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.22	WA224	Volume all water exported: internal and external	NR	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.12	WA7	Volume water sourced: all	101.6	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.17b	WA91	Volume raw-PT water supplied: residential	21.9	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	26.9	ML	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10a	WS11	Water restriction duration: PWCM	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Windorah Raw Water	Raw-Partially treated water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Windorah Raw Water	Raw-Partially treated water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Windorah Raw Water	Raw-Partially treated water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from Jundah, and can be transported by road. Supply is available immediately.

Scheme	Scheme Type	KPI code	SWIM code	Indicator title	Value	Units	Comments
Barcoo Shire Council WSP-wide	WSP	QG1.4a	AS1	Number water treatment plants: providing full treatment	3	Count	
Barcoo Shire Council WSP-wide	WSP	QG1.1	AS2	Length water mains	21.3	km	
Barcoo Shire Council WSP-wide	WSP	QG1.4b	AS47	Capacity of water treatment plants	0.21	ML/day	
Barcoo Shire Council WSP-wide	WSP	QG1.7	AS48	Total potable water storage volume	1	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.23	AS56	Volume water lost: potable water	17.6	ML	Mostly consists of water used for WTP operations such as backwashing and mains scouring.
Barcoo Shire Council WSP-wide	WSP	QG4.5	AS8	Water main breaks per 100 km water main	18.8	per 100 km water main	
Barcoo Shire Council WSP-wide	WSP	QG4.12	CS10	Water service complaints per 1000 connections	23.9	per 1000 connections	
Barcoo Shire Council WSP-wide	WSP	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	0	per 1000 connections	
Barcoo Shire Council WSP-wide	WSP	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	31	per 1000 connections	
Barcoo Shire Council WSP-wide	WSP	QG4.7	CS17	Average frequency unplanned interruptions: water	9.5	per 1000 connections	
Barcoo Shire Council WSP-wide	WSP	QG1.13	CS2	Connected residential properties: water	0.28	000s	
Barcoo Shire Council WSP-wide	WSP	QG1.14	CS3	Connected non-residential properties: water	0.139	000s	
Barcoo Shire Council WSP-wide	WSP	QG4.8a	CS66	Percent CSS response target met: water incidents	100	%	
Barcoo Shire Council WSP-wide	WSP	QG4.10	CS9	Water quality complaints per 1000 connections	7.2	per 1000 connections	
Barcoo Shire Council WSP-wide	WSP	QG3.9	FN1	Revenue: all (NPR) water	224.5	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.11	FN11	Costs: operating water per connection	1106.54	\$/connection	
Barcoo Shire Council WSP-wide	WSP	QG3.1	FN14	Capital expenditure: water supply	1935.615	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.3	FN26	Capital works grants: water	292.392	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.11a	FN32	Costs: operating water (NPR)	463.64	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.21	FN49	Costs: any other water	244.593	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.7	FN74	Current replacement costs: fixed water assets	13288.26	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.13	FN76	Costs: maintenance water	122.259	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.15	FN78	Current cost depreciation: water	244.593	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.17	FN80	Previous 5 year average annual renewals expenditure: water	95.5	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.19	FN82	Forecast 5 year average annual renewals expenditure: water	177.873	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG3.5	FN9	Nominal written down replacement cost: fixed water assets	8288.489	\$,000	
Barcoo Shire Council WSP-wide	WSP	QG4.1(value)	PR3	Fixed charge: water value	807	\$/annum	The figure shown is the minimum water bill and includes both the potable and non-potable supply usage as Council does not itemise the two in its base allocation.
Barcoo Shire Council WSP-wide	WSP	QG4.3	PR47	Annual bill based on 200kl/a: water+sewerage	807	\$	Water bill only. No sewerage service provided.
Barcoo Shire Council WSP-wide	WSP	QG4.4	PR48	Typical residential bill: water+sewerage	807	\$	Water bill only. No sewerage service provided.
Barcoo Shire Council WSP-wide	WSP	QG4.1(text)	PR5	Fixed charge: water description	Fixed charge includes access charges and the first 300kL (potable) and 700kL (raw) free. Excess water usage charges apply to amounts greater than these.	Text	
Barcoo Shire Council WSP-wide	WSP	QG1.8	WA1	Volume water sourced: surface water	281.3	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.9a	WA2	Volume water sourced: groundwater	0	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.5	WA201	Maximum daily demand	1.1	ML/day	
Barcoo Shire Council WSP-wide	WSP	QG1.21	WA223	Volume all water imported: internal and external	0	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.22	WA224	Volume all water exported: internal and external	0	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.6a	WA225	Volume potable water produced at a water treatment plant	53.1	ML	The difference between the water sourced and water produced/supplied into the system is the volume of water used for WTP operations such as backwashing etc.
Barcoo Shire Council WSP-wide	WSP	QG1.11	WA26	Volume recycled sewage supplied: all	NR	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.17a	WA32	Volume potable water supplied: residential	15.1	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.18a	WA34	Volume potable water supplied: non-residential	15.2	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.10	WA61	Volume water sourced: desalination marine water	0	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.12	WA7	Volume water sourced: all	281.3	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.17b	WA91	Volume raw-PT water supplied: residential	59.2	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	71	ML	
Barcoo Shire Council WSP-wide	WSP	QG1.20	WF1	Total full-time equivalent water+sewerage employees	1	FTEs	
Barcoo Shire Council WSP-wide	WSP	QG2.10a	WS11	Water restriction duration: PWCM	365	days	
Barcoo Shire Council WSP-wide	WSP	QG2.10b	WS12	Water restriction duration: Level 1	0	days	
Barcoo Shire Council WSP-wide	WSP	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
Barcoo Shire Council WSP-wide	WSP	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
Barcoo Shire Council WSP-wide	WSP	QG2.10e	WS15	Water restriction duration: Level 4	0	days	
Barcoo Shire Council WSP-wide	WSP	QG2.10f	WS16	Water restriction duration: Level 5	0	days	
Barcoo Shire Council WSP-wide	WSP	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
Barcoo Shire Council WSP-wide	WSP	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
Barcoo Shire Council WSP-wide	WSP	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
Barcoo Shire Council WSP-wide	WSP	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken in last 10 yrs?	yes	yes/no	Existing asset capability is being maintained and is adequate to meet demand. Existing contingency supplies are understood however additional contingency options to be investigated in the next three years, subject to funding.
Barcoo Shire Council WSP-wide	WSP	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	no	yes/no	Based on no predicted population growth over the next 5 years. ABS data shows shire population is declining.
Barcoo Shire Council WSP-wide	WSP	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	4	1,2,3,4,5,6	
Barcoo Shire Council WSP-wide	WSP	QG2.13	WS23	Confidence water demand will be met: next 18 mths	fair	high,fair,unsure,low,very low	
Barcoo Shire Council WSP-wide	WSP	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	fair	high,fair,unsure,low,very low	
Barcoo Shire Council WSP-wide	WSP	QG2.3	WS3	Available contingency supplies	yes	yes/no	Water is available from either Windorah or Jundah, and can be transported by road. Supply is available immediately.